

Project:  
Location:  
Contract:  
Engineer:  
Filename: 2020

**ETAP**  
**12.6.0H**  
  
Study Case: LF

Page: 6  
Date: 01-29-2020  
SN:  
Revision: Base  
Config.: Normal

---

---

**SUMMARY OF TOTAL GENERATION, LOADING & DEMAND**

	<u>MW</u>	<u>Mvar</u>	<u>MVA</u>	<u>% PF</u>
Source (Swing Buses):	1006.187	101.017	1011.245	99.50 Lagging
Source (Non-Swing Buses):	0.000	0.000	0.000	
Total Demand:	1006.187	101.017	1011.245	99.50 Lagging
Total Motor Load:	0.000	0.000	0.000	
Total Static Load:	814.264	34.223	814.983	99.91 Lagging
Total Constant I Load:	0.000	0.000	0.000	
Total Generic Load:	0.000	0.000	0.000	
Apparent Losses:	191.923	66.794		
System Mismatch:	0.000	0.000		

Number of Iterations: 2