

Project:  
Location:  
Contract:  
Engineer:  
Filename: 2021

**ETAP**  
12.6.0H  
  
Study Case: LF

Page: 6  
Date: 02-05-2020  
SN:  
Revision: Base  
Config.: Normal

---

---

**SUMMARY OF TOTAL GENERATION, LOADING & DEMAND**

	<u>MW</u>	<u>Mvar</u>	<u>MVA</u>	<u>% PF</u>
Source (Swing Buses):	1052.603	167.191	1065.798	98.76 Lagging
Source (Non-Swing Buses):	0.000	0.000	0.000	
Total Demand:	1052.603	167.191	1065.798	98.76 Lagging
Total Motor Load:	0.000	0.000	0.000	
Total Static Load:	845.894	88.334	850.494	99.46 Lagging
Total Constant I Load:	0.000	0.000	0.000	
Total Generic Load:	0.000	0.000	0.000	
Apparent Losses:	206.709	78.857		
System Mismatch:	0.000	0.000		

Number of Iterations: 2