

Project:  
Location:  
Contract:  
Engineer:  
Filename: 2022

**ETAP**  
**12.6.0H**  
  
Study Case: LF

Page: 6  
Date: 02-05-2020  
SN:  
Revision: Base  
Config.: Normal

---

---

**SUMMARY OF TOTAL GENERATION, LOADING & DEMAND**

	<u>MW</u>	<u>Mvar</u>	<u>MVA</u>	<u>% PF</u>
Source (Swing Buses):	1107.545	232.258	1131.636	97.87 Lagging
Source (Non-Swing Buses):	0.000	0.000	0.000	
Total Demand:	1107.545	232.258	1131.636	97.87 Lagging
Total Motor Load:	0.000	0.000	0.000	
Total Static Load:	878.254	136.361	888.777	98.82 Lagging
Total Constant I Load:	0.000	0.000	0.000	
Total Generic Load:	0.000	0.000	0.000	
Apparent Losses:	229.291	95.896		
System Mismatch:	0.000	0.000		

Number of Iterations: 2