

Project:
Location:
Contract:
Engineer:
Filename: 2024

ETAP
12.6.0H

Study Case: LF

Page: 6
Date: 02-05-2020
SN:
Revision: Base
Config.: Normal

SUMMARY OF TOTAL GENERATION, LOADING & DEMAND

	<u>MW</u>	<u>Mvar</u>	<u>MVA</u>	<u>% PF</u>
Source (Swing Buses):	1675.139	535.827	1758.750	95.25 Lagging
Source (Non-Swing Buses):	0.000	0.000	0.000	
Total Demand:	1675.139	535.827	1758.750	95.25 Lagging
Total Motor Load:	0.000	0.000	0.000	
Total Static Load:	1213.685	229.863	1235.260	98.25 Lagging
Total Constant I Load:	0.000	0.000	0.000	
Total Generic Load:	0.000	0.000	0.000	
Apparent Losses:	461.454	305.965		
System Mismatch:	0.000	0.000		

Number of Iterations: 2